

Wilson Engineered Systems, Inc.
 11501 Columbia Park Drive West, Bldg.100
 Jacksonville, FL 32258

www.wilsonengineered.com
 Phone: 904-880-0118
 Fax: 904-880-0494

Battery Test Data Report

For: **Sample**

Date 11/22/2011
 By: Wayne Thompson

Values to use as comparison points

	Impedance	Voltage	Temp
Min	3.125	13.200	
Max	4.687	14.100	

Reading Summary

Count	24.00	24.00	
Min	1.94	12.39	
Max	36.53	14.38	
Average	3.91	13.84	

	Impedance	Voltage	Temp
[1]	1.940	13.52	--
[2]	2.200	13.70	--
[3]	2.310	13.72	--
[4]	2.330	13.67	--
[5]	2.200	13.73	--
[6]	2.230	13.60	--
[7]	2.260	13.58	--
[8]	2.310	13.50	--
[9]	1.970	13.75	--
[10]	2.320	13.99	--
[11]	2.330	13.48	--
[12]	36.530	12.39	--
[13]	2.300	14.10	--
[14]	2.350	14.09	--
[15]	2.310	14.19	--
[16]	2.420	14.12	--
[17]	2.400	14.19	--
[18]	2.260	14.11	--
[19]	7.000	13.58	--
[20]	2.420	13.90	--
[21]	2.340	14.37	--
[22]	2.310	14.22	--
[23]	2.340	14.38	--
[24]	2.360	14.27	--
[END]			

